

# Annual Drinking Water Quality Report

## CITY OF NEW DEAL

Public Water System ID: TX1520015

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (XXX) XXX-XXXX.

For more information regarding this report, contact:

Name: Joe Ybarra  
 Phone: (806)746-6399

### Sources of Drinking Water

CITY OF NEW DEAL is Purchased surface water.

Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
4 - DATE ST / PLUGGED	S END OF DATE ST	Ground water		
5 - OLIVE AVE / NW CORNER OF LOT	OLIVE AVE	Ground water		
6 - OLIVE AVE (620' SE OF 5)	OLIVE AVE (620' SE OF 5)	Ground water		
7 - SOUTH OF RR 1729 (3 MI E OF TOWN)	RR 1729 (3 MI E OF TOWN)	Ground water		
8 - 190' SE OF 7	190' SE OF 7	Ground water		
9 - 1180' NW OF 8	1180' NW OF 8	Ground water		

SW FROM CITY OF LUBBOCK	CC FROM TX1520002 LUBBOCK PUBLIC WATERS	Surface water	
-------------------------	-----------------------------------------------	---------------	--

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

A service line inventory has been prepared and can be accessed 404 S. Monroe, New Deal TX. 79350, City Hall

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. CITY OF NEW DEAL is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact CITY OF NEW DEAL at 806-746-6399. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

picouries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

**Disinfectant Residual**

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Total Chlorine	2025	2.11	MGL	1.00-3.10	4/4

**Regulated Contaminants**

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2023	0.049	0.0271 - 0.0913	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2023	0	0 - 2.33	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	404 S MONROE AVE, NEW DEAL	2025	12	6	ppb	60	0	By-product of drinking water disinfection
TTHM	404 S MONROE AVE, NEW DEAL	2025	10	11.2	ppb	80	0	By-product of drinking water chlorination

  

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
DIBROMOCHLOROMETHANE	11/12/2025	5	2.38 - 5	UG/L	0	0.06	
NITRATE	12/3/2025	1.05	1.05	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	11/10/2021	1.14	1.14	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

There are no additional required health effects notices.

There are no additional required health effects violation notices.



April 3, 2026

City of New Deal  
P.O. Box 126  
New Deal, Texas 79350

To Whom It May Concern:

Please find the enclosed 2025 Water Quality Report Data for Your records. Please feel free to Contact us should you have any questions.

Thank you.

Waylan Field  
Water Superintendent  
Email: [wfield@cityofslaton.com](mailto:wfield@cityofslaton.com)  
Ph: (806) 828-2000

**WATER QUALITY REPORT DATA - 2025**

CONTAMINANT	Year of Range	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Contaminant Sources	Violation	
										SUBSTANCES REGULATED AT THE TREATMENT PLANT
BETA/PHOTON EMITTERS	2023	8.6	8.6	8.6	50 *	0	pc/l	Decay of natural and man-made deposits	NO	
ALPHA EMITTERS	2023	N/A	N/A	N/A	15	0	pc/l	Erosion of natural deposits	NO	
URANIUM	2023	5	5	5	30	0	ppb	Erosion of natural deposits	NO	
ARSENIC	2025	1.4	1.4	1.4	10	0	ppb	Erosion of natural deposits; runoff from orchards	NO	
BARIUM	2025	0.12	0.12	0.12	2	2	ppm	Erosion of natural deposits	NO	
DI (2-ethylhexyl) phthalate	2025	<0.5	<0.5	<0.5	6	0	ppb	Discharge from rubber and chemical factories	NO	
CHROMIUM	2025	1.7	1.7	1.7	100	100	ppb	Erosion of natural deposits	NO	
CYANIDE	2025	N/A	N/A	N/A	200	200	ppb	Discharge from steel/metal, plastic, and fertilizer factories	NO	
FLUORIDE	2025	0.681	0.633	0.710	4	4	ppm	Erosion of natural deposits	NO	
NITRATE	2025	1.11	1.00	1.33	1.99	10	ppm	Fertilizer runoff, septic tank leachate, sewage, erosion	NO	
TURBIDITY	2025	0.055	0.029	0.103	*** < 0.3 (TT)	0	NTU	Soil runoff	NO	
TOTAL ORGANIC CARBON	2025	1.41	0.83	1.75	TT	TT	ppm	Naturally present in environment	NO	
TOTAL CHLORINE	2025	3.71	3.00	4.30	MRDLG=4.0	MRDLG=4.0	ppm	Disinfectant used to control microbes	NO	
CHLORITE	2025	0.344	0.100	0.774	1	0.8	ppm	By-product of drinking water disinfection	NO	
<b>ADDITIONAL MONITORING AT ENTRY POINT</b>										
ALUMINUM	2025	0.133	0.047	0.208	0.05-0.2 <sup>m</sup>	N/A	ppm	Water Treatment Chemical	N/A	
CHLORIDE	2025	289	204	315	300 <sup>m</sup>	N/A	ppm	Naturally occurring	N/A	
SULFATE	2025	136	98	144	300 <sup>m</sup>	N/A	ppm	Naturally occurring	N/A	
TOTAL DISSOLVED SOLIDS	2025	870	717	991	1000 <sup>m</sup>	N/A	ppm	Naturally occurring	N/A	
AMMONIA	2025	0.162	0.050	0.379	Not Regulated	N/A	ppm	Water Treatment Chemical	N/A	
CALCIUM	2025	33.61	31.09	36.96	Not Regulated	N/A	ppm	Naturally occurring	N/A	
MAGNESIUM	2025	36.17	31.96	40.77	Not Regulated	N/A	ppm	Naturally occurring	N/A	
POTASSIUM	2025	6.94	6.41	7.77	Not Regulated	N/A	ppm	Naturally occurring	N/A	
SODIUM	2025	223	193	260	Not Regulated	N/A	ppm	Naturally occurring	N/A	
HARDNESS	2025	230	216	244	Not Regulated	N/A	ppm	Naturally occurring	N/A	
CONDUCTANCE	2025	1573	1379	1692	Not Regulated	N/A	umho/cm	Naturally occurring	N/A	
TOTAL ALKALINITY	2025	187.83	175.48	195.32	Not Regulated	N/A	ppm	Naturally occurring	N/A	

Some of our data, though representative, are more than one year old.

TT - Treatment Technique

\*The MCL for beta/photon emitters is 4 mrem/year. The USEPA considers 50 pc/L to be the level of concern for beta/photon emitters.

\*\*Running Annual Average

†Highest Locational Running Annual Average N/A - Data not available Single Readings - Average, Minimum, and Maximum given as a single Number

‡Secondary Constituent Levels set by the Texas Commission on Environmental Quality.

\*\*\* Note: 100% of plant turbidity meets the <0.3 NTU MCL

\*\*\*\*Results reported as (Presence/Absence). Presence is defined as total coliforms found (positive). Absence is defined as no total coliforms found (negative).